Mathematical Modelling of PV array and Performance Enhancement by MPPT Algorithm

Ravikumar R Patel

P.G. Student, Electrical Engineering Department, LDRP-ITR, Sector-15, Gandhinagar, 382015, Gujarat, India er.ravipatel1@gmail.com

Abstract: This paper proposes a mathematical modelling and simulation of photovoltaic array and MPPT algorithm with Boost converter. The photovoltaic array and MPPT algorithm with Boost converter can be simulated with MATLAB Simulator. The mathematical modelling of PV array model gives different PV cell behaviour under variant environmental conditions. It is seen that the output characteristics of q PV array changes due to environmental factors. So the maximum power point tracking (MPPT) technique is needed to catch the peak power to maximize the this produced In energy. paper, Perturbation &Observationalgorithm isused. This algorithm sets the suitable duty ratio in which the DC/DC converter is operated to MPP. This paper outlines the working of PV array as well as MPPT algorithm.

Keywords- Matlab, Simulation, Solar Cell Model, V_{mpp}, I_{mpp}, Maximum power Point Tracking, P&O Algorithm, Boost Converter.

I. INTRODUCTION

Demand and supply of the energy are vital factors in the economic growth. The global demand of energy is increasing day by day with the economic growth. Renewable energy sources has been increasingly used in order to develop clean and sustainable energy sources as they possess several advantages like their suitability for decentralized use, they areclean source of energy,possess no potential damage to the environment, widely available unlike fossil fuel sources which are concentrated at some locations only. Popular renewable energy sources are solar energy, Tidal energy, geothermal energy, Wind energy, Bio energy, Hydro energy.

Use of Solar Photovoltaic is increasing day by day and it is now preferred as a clean source of energy with no CO2emission. Several countries have started ambitious programs in search of renewable energy sources. The obvious choice of a clean energy source, which is abundant and could provide security for the future development and growth, is the solar energy. Solar energy is one of the most important renewable sources of energy. India has high solar insolation. It is an ideal place for using solar power. But the high installation cost of PV system and the low conversion efficiency of PV modules are the major obstacles for using this alternative energy source on a large scale. So several studies are being developed in order to minimize these disadvantages. [1]-[9]. Therefore, a maximum power point tracking (MPPT) control method to achieve maximum power (MP) output at real time becomes necessary in PV generation systems.

Tapan A Trivedi

Professor, Electrical Engineering Department, LDRP-ITR, Sector-15, Gandhinagar, 382015, Gujarat, India trivedi_tapan2007@yahoo.com

There are different techniques used to track the maximum power point. Few of the most popular Techniques are:

- > Perturb and Observe (hill climbing method)
- Incremental Conductance method
- ➢ Fractional short circuit current
- Fractional open circuit voltage
- Neural networks
- Fuzzy logic

Among them Perturb and Observe (hill climbing method) method has drawn much attention due to its simply implementation. But the oscillation issues in this method is unavoidable.

II. PV PANEL MODEL

A PV array consists of several photovoltaic cells in series and parallel connections. Series connections are responsible for increasing the voltage of the module whereas the parallel connection is responsible for increasing the current in the array.

Typically a solar cell can be modelled by a current source and an inverted diode connected in parallel to it. It has its own series and parallel resistance. Series resistance is due to hindrance in the path of flow of electrons from n top junction and parallel resistance is due to the leakage current.Figure1.1shows single diode model of a PV cell.




Figure 1.1 Single diode model of a PV cell

In this model we consider a current source (I_L) along with a diode and series resistance (Rs). The shunt resistance (R_{SH}) in parallel is very high, has a negligible effect and can be neglected.

The output current from the photovoltaic array is

$$I = I_L - I_d - \frac{V_0}{R_{sh}}(1)$$

Where,

$$V = V_0 - R_s I(2)$$

The basic equation for the ideal case of the elementary PV cell does not represent the I-V characteristic of a practical PV array, actually Practical arrays are composed of several connected PV cells and the observation of the characteristics at the terminals of the PV Array is expressed by considering one the parameter called "I" which is given by:

$$I = I_l - I_d \left[\exp\left(\frac{q(V+R_s I)}{nkt N_s}\right) \right] - 1(3)$$

In the above mentioned equation, the parameter I_L and I_0 are expressed as:

$$I_{l} = I_{L(T_{r})}(1 + \alpha_{I_{se}}(T - T_{r}))$$
(4)

$$I_o = I_{0(T_r)} \left(\frac{T}{T_r}\right) \exp\left[\frac{qV_g}{nk} \left(\frac{1}{T} - \frac{1}{T_r}\right)\right](5)$$

Where $I_{L(T_r)}$ is :

$$I_{L(T_r)} = G\left(\frac{I_{sc(T_r,nom)}}{G_e}\right) \qquad (6)$$

Where $I_{0(T_r)}$ is a reverse saturation current.

$$I_{0(T_r)} = \frac{I_{sc(T_r)}}{\exp\left(\frac{q(V_{oc}(T_r))}{nk T_r N_s}\right) - 1} (7)$$

Where,

$$\alpha_{I_{sc}} = \frac{dI_{sc}}{dT}(8)$$


Here,

- \blacktriangleright I_L: light or photo current.
- ➢ Io: reverse saturation current of the diode.
- ➢ Is, Vs: the output current and voltage of the photovoltaic generator respectively.
- > q: charge on electron.
- ➢ K: Boltzmann's constant.
- ➢ Rs: series resistance.
- > n: Ideality factor for P-N junction.

III. CONTROL ALGORITHM FOR MPPT PERTURBATION& OBSERVATION (P & O) METHOD

Perturbation & Observation (P & O) is the simplest method. In this we use only one sensor, that is the voltage sensor, to sense the PV array voltage and so the cost of implementation is less and hence easy to implement. The time complexity of this algorithm is very less but on reaching very close to the MPP it doesn't stop at the MPP and keeps on perturbing on both the directions. When this happens the algorithm reaches very close to the MPP and we can set an appropriate error limit or can use a wait function which ends up increasing the time complexity of the algorithm. However the method does not take account of the rapid change of irradiation level (due to which MPPT changes) and considers it as a change in MPP due to perturbation and ends up calculating the wrong MPP. To avoid this problem we can use incremental conductance method.

The Perturb and Observe is one of the so called 'hillclimbing' MPPT methods, which are based on the fact that, on the voltage-power characteristic, on the left of the MPP the variation of the power against voltage dP/dV >0, while on the right, dP/dV < 0.



In Fig.1.2, if the operating voltage of the PV array is perturbed in a given direction and dP/dV > 0, it is known that the perturbation moved the array's operating point toward the MPP.

The P&O algorithm would then continue to perturb the PV array voltage in the same direction. If dP/dV < 0, then the change in operating point moves the PV array away from the MPP, and the P&O algorithm reverses the direction of the perturbation.

The main advantage of the P&O method is that it has low computational demand,easy to implement and is very generic, i.e. applicable for most systems as it do not require any information about the PV array, but only about the measured voltage and current.

The main problems of the P&O is the oscillations around the MPP even in the steady state condition, and poor tracking (possibly in the wrong direction, away from MPP) under rapidly-changing irradiations.

The flowchart for the P&O algorithm is shown in Figure 1.3.




Figure 1.3: Flowchart of Perturb & Observe Algorithm

IV. SIMULATION SETUP AND RESULTS

A. PV Array simulation

All of the model parameter can be determined by examining the manufacturer's specifications of the PV products. The important parameters used for the penal electrical performance is the open circuit voltage (V_{oc}) and short circuit current (I_{sc}).

Parameters	Specifications
I _{mp}	7.61 A
V _{mp}	26.3 V
P _{max}	200.143 W
I _{sc}	8.21 A
V _{oc}	32.9 V
K _v	-0.1230 V/K
$\alpha_{I_{sc}}$	0.00032 V/K
N _s	54
Io _(Tr)	9.2825*10 ⁻⁸ A
n	1.3
R _p	415.405
R _s	0.221

Table 1:- Solar array KC200GT Specification (1000 W/m², 25° C)




Figure 1.5 PV panel model

Fig 1.5 shows the mathematical simulation of the Solar panel with different subsystem.






Figure 1.6 Subsystem of Current generated by illumination (I_L)









Figure 1.8 Subsystem of Saturation current Io

B. Simulation Results of the PV

A) I-V curve



B) P-V curve




Figure 1.10P- V curve.

V. SIMULATION OF PV ARRAY, DC/DC BOOST CONVERTER WITH MPPT ALGORITHM




Figure 1.11DC/DC Converter with MPPT Algorithm.




Figure 1.12P & O Algorithm.

By using the Step block in the MATLAB one can change the irradiation level. Figure 1.12 and figure 1.13 shows I-V and P-V Curve of the PV array and also the changes in the irradiation level 1000 G to 800 G.




Figure 1.13I-V curve for1000 G to 800 G




Figure 1.14P-V curve for1000 G to 800 G




Figure 1.15Input Current of DC/DC Converter for 1000 G to 800 G




Figure 1.16 Input Voltage of DC/DCConverter for 1000 G to 800 G

IJLTEMAS




Figure 1.17Input Power of DC/DCConverter for 1000 G to 800 G




Figure 1.18Output Current of DC/DCConverterfor 1000 G to 800 G

Figure 1.19Output Voltage of DC/DCConverterfor 1000 G to 800 G

Figure 1.20 Output Power of DC/DCConverter for 1000 G to 800 G

VI. CONCLUSION

This paper shows the development of a method for the mathematical modelling of the PV array and simulation model of DC/DC boost converter with MPPT algorithm. The objective of the method is to satisfy the mathematical I-V equation with the experimental remarkable points of the I-V curve of the practical Array. The method obtains the parameters of the I-V equation by using following nominal information like open circuit voltage, short-circuit current, maximum output power, voltage and

current at the MPP, current/temperature and voltage temperature coefficientsfrom the array datasheet. This paper also presents the simulation of DC-DC boost converter with MPPT algorithm. Figure 1.11 shows the implementation of the DC-DC Converter with MPPT. Figure 1.12 to Figure 1.20 shows the input Current and Voltage, output Current and Voltage, Input Power, Output Poweras well as P & O algorithm. Simulation shows how the MPP is tracked using Perturbation & Observation (P & O) algorithm to maximize the power output of the PV array.

REFERENCES

- Chetan Singh Solanki, "Solar Photovoltaic Fundamentals, technologies and Applications", Second edition, published by Asoke K. Ghosh, 2011, PHI Learning Private Limited, New Delhi.
- [2] Resource and Energy Economics C Withagen 1994 Elsevier.
- [3] Semana Scientífica L Pedroni 2004 Google Books
- [4] Effichios Kourtoulis, Kostas Kalaitzakis, "Development Of a Micro-controller Based, Photovoltaic Maximum Power Point Tracking Control System, IEEE Transactions on Power Elctronics, VOL. 16, No. 1, January 2001.
- [5] Weidong Xiao, William G. Dunford, "A Modified Adaptive Hill Climbing MPPT Method for Photovoltaic Power Systems, 35th Annual IEEE Power Electronics Specialisrs Conference, pp. 1957-1963, June 2004.
- [6] Trishan Esram, Patrick L. Chapman "Comparison of Photovoltaic Array Maximum Power Point Tracking Techniques," IEEE Transaction on Energy Conservation, VOL. 22, NO. 2, June 2007.
- [7] Ting-Chung Yu, Yu-Cheng Lin "A Study on Maximum Power Point Tracking Algorithms for Photovoltaic Systems", December 2010.
- [8] Marcelo Gradella Villalva, Jonas Rafael Gazoli, and Ruppert Filho on 'Comprehensive Approach to Modelling and Simulation of Photovoltaic Arrays'
- [9] Power Electronics, Converters, Applications and Design, Book by Mohan, Undeland, RiobbinsIEEE Transaction on Power Electronics, VOL., 24, NO. 5, MAY 2009.
- [10] R. Messenger and J. Ventre, Photovoltaic Systems Engineering, CRC Press, 2000, pp.41-51.
- [11] S. W. Angrist, Direct Energy Conversion, Allyn and Bacon, Inc., 4th edition, 1982, pp. 177-227.
- [12] O. Wasynczuk, "Dynamic behavior of a class of photovoltaic power systems," IEEE Transactions on Power Apparatus and Systems, vol. PAS-102, no. 9, 1983, pp. 3031-3037.
- [13] C. C. Hua and C. M. Shen, "Study of maximum power tracking techniques and control of dc-dc converters for photovoltaic power system," Proceedings of 29th annual IEEE Power Electronics Specialists Conference, vol. 1, 1998, pp. 86-93.
- [14] M. Veerachary and K.S. Shinoy, "V2 nonlinear PV sources," IEE Proceedingsvol. 152, no. 5, 2005, pp. 1263-1270.
 [15] I. S. Kim and M. J. Youn, "Variable-structure observer for
- [15] I. S. Kim and M. J. Youn, "Variable-structure observer for solar array current estimation in a photovoltaic power Proceedings-Electric Power Applications, vol. 152, no. 4, 2005, pp. 953 959.
- [16] I. S. Kim, M. B. Kim, and M. J. Youn, "New maximum power point tracker using sliding-mode observer for estimation of solar array cu in the grid-connected photovoltaic system," IEEE Transaction on Industrial Electronics, vol. 53, no. 4, 2006, pp. 1027